

R.No. 1565/CC
22-5-17



OFFICE OF THE MEDICAL SUPERINTENDENT
J. N. MEDICAL COLLEGE HOSPITAL
A.M.U., ALIGARH

No. Ext. 356 /MCH

Date: 22/5/2017

CORRIGENDUM

With refer to our NIT No. 292/MCH/Nazeer dated 13.05.2017 wherein calling the Tender/quotations for 20 KVA online (U.P.S).

The following changes have been made in the specification of online (U.P.S). The detail is as given below:-

Online U.P.S with the following specification:

2x20 KVA, 3 phase with by pass arrangement and one hour back up (Exide/Amron Battery Including Battery Rack) and output voltage 230v with incoming isolater (100 Amp. MCCB) and Comprehensive onsite warranty 03 years.

The date and other terms of conditions of NIT will remain same.

Medical Superintendent

Medical Superintendent
J.N. Medical College Hospital
A.M.U., ALIGARH