

No. Ext 132 /MCH

R.No. 1328/CC
28/04/2017 Dated 27/4/2017

Notice Inviting Tender/Quotation

As per requirement during Financial Year 2017-2018

Sealed quotations/tenders are invited for the following work on the terms & conditions printed over leaf. Quotation should reach this office on or before 18.05.2017 by 3:00 P.M.

Supply & Installation of Sound Proofing of Audiometric Room for ENT OPD at JNMCH

S. No.	Particulars
1.	STEEL SPECIFICATION:
	A. GI CHANNEL : B. WIRE MESH : C. SCREW, NUT, BOLT, ETC :
	MADE BY GI SHEET OF TATA/SAIL CO 24 SWG BEST QUALITY STAINLESS STEEL
2.	NOISE ABSORBENT MATERIAL SPECIFICATION:
	A. INSULATION WOOL : B. ACCOUSTIC TILES :
	IS8183, LOW THERMAL CONDUCTIVITY, WATER REPELLENT, CHEMICALLY NEUTRAL WITH HIGH TEMPERATURE RESISTANCE (500 C), NON COMB. ARE USED FOR MAX. SOUND REDUCTION 100 MM THICK 96KG/M3 FOR WALL 12 MM THICK ACCOUSTIC TILES HAVING 0.8 NRC AND ADEQUATE PERFORATION FOR ECHO CONTROL
3.	SEALING MATERIAL SPECIFICATION:
	A. EDPM GASKET : B. SEALENT :
	HIGH QUALITY ASP EDPM GASKET AIS ISO CERTIFIED COMPANY IS USED TO SEAL THE GATE WELL REPUTED SEALENT ARE USED TO SEAL STEEL TO STEEL PANEL
4.	HARDWARE SPECIFICATION:
	A. LOCKS/HANDLES : B. HINGES (STAINLESS STEEL) :
	HIGH QUALITY CASTED BOTH SIDES OPERATED NICKLE PLATED HEAVY DUTY DEEP FREEZER LOCKS ARE USED HEAVY DUTY CRC SHEET HEAVY DUTY LORRY HINGES ARE USED FOR LONG LIFE USE
5.	DOOR SPECIFICATION:
	A. WOODEN ACCOUSTIC DOOR :
	FABRICATING AND FIXING 4" thick WOODEN ACCOUSTIC SOUND REDUCING DOOR, INFILL IN 96 KG/M3 DENSITY ACCOUSTIC SLAB ON BOTH SIDES, DOOR WOULD HAVE STAINLESS STEEL HINGES WITH BALL BEARING, LONG STAINLESS STEEL DOOR HANDLES
6.	VIEWING GLASS WINDOW SPECIFICATION:
	A. DOUBLE GLASS :
	ONE DOUBLE GLAZED UNIT COMPRISES 6MM THICK SAFETY GLASS FITTED IN ALUMINIUM FRAMES CLEAR VIEW 600MM HIGH X 600MM WIDE
7.	JACK PANEL:
	A. JACK PANEL :
	A JACK PANEL CONSISTING OF TWELVE 6.4 MM THREE-POLE JACK SOCKETS SHALL BE PROVIDED BELOW THE WINDOW

Note:

1. Only typed quotations/tenders on original letter head will be entertained.
2. Cutting/overwriting on quotations/tenders will not be considered.
3. Installation Charges, if any should be clearly mentioned.
4. Warranty should be mentioned, if any.

Medical Superintendent
Medical Superintendent
J.N. Medical College Hospital
A.M.U., ALIGARH

