

DEPARTMENT OF ELECTRICITY, SUPPLY SERVICE SECTION
ALIGARH MUSLIM UNIVERSITY, ALIGARH

D.No.909.

Date: 05.10.2013

Quotations are invited for **11/0.433 Kv** Transformers BEE Star rated specifying losses at **No load,50% 75% and 100%** loads of under mentioned ratings and specifications with standard and optional accessories.

630 KVA, 11/0.433 Kv 50 HZ

400 KVA, 11/0.433 Kv 50 HZ

250 KVA, 11/0.433 Kv 50 HZ

160 KVA, 11/0.433 Kv 50 HZ

Note:

VOLTAGE RATIO 11/0.433 KV, COPPER WINDING, ONAN TYPE OIL COOLED, DELTA STAR CONNECTION, Dyn - 11 VECTOR GROUP HV & LV BUSHING, OFF LOAD CIRCUIT TAP CHANGER, $\pm 7.5\%$ @ 2.5%.

The rates for optional items may be quoted separately.

The rates quoted may be with general terms and conditions of delivery at A.M.U.Aligarh (including freight) along with terms and conditions of delivery and payments. Excise duty / Tax / VAT may be specified separately.

The quotations under sealed cover should be submitted up to **20.10.2013** along with copy of registration with government approved offices/agencies & PAN / TIN should be specified.

Guarantee of Transformer with after sales Service facility and availability of spare parts may be specified.

Electrical Engineer
(Supply Service Section)