

Notice Calling or Quotation/Tender
Telephone Department, AMU Aligarh

D. No.:.....

Dated: 02.09.2013

Sealed Quotations/Tender are invited for laying of underground cable in sealed cover before 2:00 pm on 14.09.2013 in the office of the Member-in-Charge (Telephones) AMU Aligarh. The quotations shall have the validity of at least 6 months.

Interested contractors/firms may quote the rates on running meter basis for digging, filling and laying underground jelly filled copper cable as per following specifications:

Specifications:

1. The trenching depth should be 3 feet with a width of 1.23 feet.
2. Sand shall be laid at the bottom of trench in 3 inches thickness.
3. Cable is to be laid in the trench in a straight length as far as possible.
4. Cable is to be buried under 3 inch thick sand layer as a second course.
5. Second class brick layer shall be placed over second layer of sand.
6. Back filling of available excavated earth in layers not exceeding 30 cm with proper watering and compaction to make as good as original.
7. Remaining balance earth shall be disposed off at a suitable place with no extra payment.
8. Rate quoted shall include operations from 1 to 7 above.

Rates for the following may be quoted:

S.No	Approx Quantity	Particular/Specification
1	1 meter	Excavation trenching/raffling ramming all type Kachha surface including stone and kharanja.
2	1 meter	Supply of sand.
3	1 meter	Supply of brick second class.
4	1 meter	Boring under the road where trenching is not possible.
5		Jointing of cable
6	Per DB	Erections, fitting, fixing of DB post
7	1 meter	Laying of cable and trench
8	Per DB	10/20/50/100/200 pair
9	1 meter	GI pipe 2.5 inch
10	1 meter	H.D.P.E. pipe
11		Punching of cable per pair
12	1 Nos	Krone
13	1 Nos	D.B. Cemented foundation
	1 Nos	Fitting D.B.on Wall

Member – in-Charge (Telephones)